



Bangalore Electricity Supply Company Limited

No.: BESCOM/NC_LTPWRSA/0989142471/31-03-2021

GSTIN Number: 29AACCB1412G1Z5

Office of
Assistant Executive Engineer
N5 SRS GATE
BESCOM
DATE: 31-03-2021

To,
A E E BBMP SHETTYHALLI SUB DIVISION DASARAHALLI ZONE,
2ND MAIN ROAD MALASANDRA

BANGALORE KARNATAKA
560057

Sir/Madam,

Sub: Arranging LT power supply-NEW CONNECTION

Ref: 1) Application No:320320252725 Dated: 30-03-2021
2) Account ID : 9247530118
3) Prevailing KERC regulations.

With reference to your Application No. 320320252725 Dated: 30-03-2021, power supply to an extent of 0 KW and 8 HP on Account ID 9247530118 under LT basis, is hereby sanctioned, subject to the following:

1. Details of your building/premises:

a. Plinth area:

Page 1 of 4

Account ID : 9247530118

Consumer Name : A E E BBMP SHETTYHALLI SUB DIVISION DASARAHALLI ZONE

1	No. of Floors Existing	0
2	No. of Floors Added or New	0
3	Existing Plinth Area in sq.m.	0
4	Added or New Plinth Area in sq.m.	0
5	Total Plinth Area in sq.m.	0

b. Total height of the building above ground level in m: 0

2. The **PROPOSED** Sanctioned Load of your building is **5.968 KW**

Existing Load Details of your premises:

1	Existing Sanctioned Load	0
2	New/ Additional Load Required	0 KW and 8 HP
3	Total Load	5.968 KW

You are requested to pay the following charges by Cash/ DD (above ₹10000/-, only DD will be accepted) in favour of **The Assistant Executive Engineer (EI) N5 SRS GATE, BESCO** within 30 days from the date of this letter.

Sl. No.	Particulars	Amount	CGST	SGST	Total Amount
1.	2 MMD to be for 1 Nos (of 0 KW and 8 HP) installation	₹7810.00	₹0.00	₹0.00	₹7810.00
2.	MSD Amount	₹0.00	₹0.00	₹0.00	₹0.00
3.	Infrastructure Charges	₹0.00	₹0.00	₹0.00	₹0.00
4.	Service Line Cost(Development Charge)	₹0.00	₹0.00	₹0.00	₹0.00
5.	Additional Development /Service Line Charges	₹0.00	₹0.00	₹0.00	₹0.00
Total					₹7810.00

Note: 2 MMD/MSD shall be paid separately for individual installations (separate Payment Receipts to be drawn).

3. The power supply will be arranged at 400V

4. The Power Tariff applicable to your proposed installation will be **Monthly LT6A tariff schedule for metered customers(BESCO)** Tariff, or as in force from time to time

5. You have to confirm to purchase High precision/Electrostatic meters/ETV meters of the following capacity:

Account ID : 9247530118

Consumer Name : A E E BBMP SHETTYHALLI SUB DIVISION DASARAHALLI ZONE

Page 2 of 4

a) Single Phase Meters _____ Nos.

b) Three Phase Meters _____ Nos.

c) ETV Meters _____ Nos.

d) TP box with _____ CTR _____ Nos.

6. After the payments, the following requirements may please be fulfilled:

- a) Execute agreement of power supply on ₹200/- Stamp Paper in duplicable, for individual installations in the prescribed format
- b) Produce necessary License/Permit/No Objection Certificate etc., issued by the Competent Authority, as required under the statute

7(a) The Power supply will be arranged by **BESCOM** as below:

- a) From the existing _____ KVA Transformer
- b) After enhancement of TC capacity from _____ KVA to _____ KVA of the TC located at _____
- c) After erecting new _____ KVA transformer under service connection

7(b) If you intend to install distribution transformer inside your premises, and execute the work under self-execution, to avail above power supply, the following shall be complied:

- i. An electrical room with RCC roof having clear floor area of 5 metres X 4 metres, with a vertical clearance of 2.75 metres with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor, within the Applicant's premises nearer to the main entrance, for installing floor mounted distribution transformer and associated switchgear, or
- ii. A clear space of 3 metres X 5 metres open to the sky shall be provided, within the Applicant's premises, preferably at the main entrance, for installing structure mounted distribution transformer and switchgear

8. **BESCOM** approved suitable capacity circuit breaker, ELCB & switchgears shall be used, and all the provisions under KERC Regulations 4.03 and 4.04 shall be complied

9. **BESCOM** reserves the right to cancel power supply and forfeiting of the Deposits paid by you, if the documents submitted by you are found to be fake

10. As per the Govt. Order, solar water heaters of suitable capacity shall be provided

11. Five nos. of Compact Fluorescent Lamps shall be used for each installation

12. The metering equipment to be installed should be conspicuously visible and at the main entrance to the premises, preferably with an independent entrance.

You are requested to contact the undersigned in case of any other information that may be required by you.

We remain at your services.



Yours faithfully

Assistant Executive Engineer

N5 SRS GATE

BESCOM

Page 3 of 4

Account ID : 9247530118

Consumer Name : A E E BBMP SHETTYHALLI SUB DIVISION DASARAHALLI ZONE

TAX INVOICE

(See Rule 46 of the Central Goods & Services Tax Rules, 2017)

Landis+Gyr Limited**ಲ್ಯಾಂಡಿಸ್+ಗೆರ್ ಲಿಮಿಟೆಡ್****Landis+Gyr****R. O. Address :**No. 503, 1st Floor, 3rd Main,
50 Feet Road, Hanumanthnagar,
BENGALURU - 560050.
Ph.: 080-26678515**Branch Office Address :**O/o AEE (C, O&M), N-4 Sub-Division,
BESCOM, Peenya 2nd Stage,
BENGALURU - 560058.

Customer Name	AEE BBMP
Address	Shetty Halli T.D. Halli Boe
GSTIN :	


BILL No.	PNY/21/ 00560
DATE :	16/11/2021 TIME 5.45 AM/PM
GSTIN :	29AAACV9922B1ZA

Sl. No.	Description of Goods / Services	Quantity (Nos.)	Rate per Pc Rs.	Value Amount Rs.	P.
	HSN Code : 90283010 Single / Three Phase Static Energy Meter Model : E150 / E250, 5-30 Amps Serial Nos. <u>3ph</u> <u>E0677928</u>	01	1266.6	1266.6	6
BESCOM DVN : <u>21-5</u>		CGST @ 9%		132	00
W.O. No. <u>6-18033</u> Date <u>15/11/2021</u>		SGST @ 9%		132	00
Total Invoice Value (In Words) : <u>one hundred and twenty six thousand six hundred and sixty six</u>		GRAND TOTAL		1730.6	6

E.&O.E.

- 1st Copy Original : White
 2nd Copy Duplicate : Pink
 3rd Copy Triplicate : Yellow
 4th Copy Extra : Blue

For Landis+Gyr Limited



Signature

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ
BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

TEST CERTIFICATE

Date : 07 APR 2021

This is to certify that the meter received from M/s. Landis+Gyr Limited is tested good.
It is sealed in the MT laboratory having the Meter & Seal details as below.

Meter Details :

Make : Landis+Gyr	3P, 4W, Whole Current	3 x 240V (L-N)
Type : ZMI310	4000 Imp/kWh	5-30A
Class : 1.0	50 Hz.	

Sl. No.: 6067922 initial reading 00000

The meter is sealed with Polycarbonate seal with Sl. No. 18MF 18049

Asst. Executive Engg. (Ele.)
BMAZ, BESCOM,
Bangalore